





Alarm Logger – Emerson Ovation DCS

Rajnikant K

Alarm Printing define steps

3/20/20





4 - HyperTerminal

```

FA# 176 1 1 0 Alarm Type Code N
10/6/2019 3:38:08 PM RETURN 5
ZT101-LDC Adm. Actuator Po
sition (LDC) 1
99.33 V
19 3:35:28 PM ALARM D
10/6/2019 3:38:12 PM SENSOR 5
ZT101-LDC Adm. Actuator Po
sition (LDC) 1
-0.21B V
10/6/2019 3:39:21 PM DROP11 RETURN 5
ZT101-LDC Adm. Actuator Po
sition (LDC) 1
99.33 V
10/6/2019 3:39:25 PM SENSOR 5
ZT101-LDC Adm. Actuator Po
sition (LDC) 1
-0.20B V
66 11 0 0
10/6/2019 3:35:28 PM ALARM D
ROP210 DROP210 2

```

COM4 Properties

Post Settings

Bits per second: 9600

Data bits: 7

Parity: Even

Stop bits: 1

Flow control: None

4 Properties

Country/region: India (SI)

Area code: 51

Phone number:

Connect using: COM4

Use country/region code as prefix on busy

Date	Alarm Type	Message	Severity	Priority	Alarm Code	Alarm Description	Alarm Status
5/26/2019 9:04:02 AM	RETURN						
5/16/2019 10:35:16 AM	RETURN						
5/16/2019 8:26:45 AM	RETURN						
5/16/2019 8:26:45 AM	RETURN						
5/16/2019 8:03:55 AM	RETURN						
5/16/2019 8:03:55 AM	RETURN						
5/16/2019 7:44:41 AM	RETURN						
5/16/2019 7:44:41 AM	RETURN						
5/4/2019 9:30:26 AM	ALARM						
5/2/2019 9:27:16 AM	ALARM						
4/30/2019 9:02:15 AM	ALARM						
4/28/2019 9:32:01 AM	ALARM						
4/24/2019 12:05:07 PM	ALARM						
4/17/2019 9:32:52 PM	ALARM						
4/17/2019 9:32:52 PM	RETURN						
4/17/2019 1:04:33 PM	ALARM						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:30 PM	SENSOR						
4/17/2019 1:04:29 PM	SENSOR						
4/17/2019 1:04:29 PM	SENSOR						
4/17/2019 1:04:29 PM	SENSOR						
4/17/2019 12:50:31 PM	SENSOR	SPV308A-POS	0	0	0.0	ECT	
4/17/2019 12:50:31 PM	SENSOR	SPV309A-POS	0	0	0.0	ECT	
4/17/2019 12:50:31 PM	SENSOR	STTRB-POS	0	0	0.0	ECT	
4/17/2019 12:50:31 PM	SENSOR	STTRB-POS	0	0	0.0	ECT	
4/17/2019 12:03:51 PM	ALARM	SC SZS104-ALARM	3	U		ALARM 1	U
4/17/2019 12:03:49 PM	ALARM	5DBMPRAI	2	U		TRUE 1	U
4/17/2019 12:03:49 PM	ALARM	5DBHTURTRP	1	U		TRIP 1	U
4/17/2019 12:03:48 PM	ALARM	STT025A-TRP	1	U		TRIP 1	U
4/17/2019 12:03:48 PM	ALARM	STT001-TRP	1	U		TRIP 1	U
4/17/2019 12:03:48 PM	ALARM	STT025-TRP	1	U		TRIP 1	U
4/17/2019 12:03:45 PM	ALARM	XVES1A-A	3	S			S
4/17/2019 12:03:45 PM	ALARM	XSE43-A	3	S			S
4/17/2019 12:03:45 PM	ALARM	SDHEA-A	3	S			S
4/17/2019 12:03:45 PM	ALARM	XVES2A-A	3	S			S
4/17/2019 12:03:45 PM	ALARM	XVES3A-A	3	S			S

Total Alarm: 576 Acknowledged: 417 Unacknowledged: 156 Reset: 3 Suppressed: 29

3:44 PM 10/6/2019

END